



BENTON COUNTY FIRE SERVICES

Marc Trollinger, Fire Marshal
215 E. Central Ave, Bentonville, AR 72712
Phone: 479-271-1004 Fax: 479-271-1084
Operations: 479-271-1005
bentoncountyar.gov

2/26/2016

Area Lake Boat and Mini- Storage

Building Classification S-2 (parking garage)
2012 Arkansas Building Code 311.3

The driving surface will need to be built to support a minimum of a 50,000lb Fire Apparatus.
2012 Arkansas Fire Code 503.2.3

Any locked gates will require an electric opening device.
2012 Arkansas Fire Code 503.6

One or more fire hydrants or other approved water supply will be required on the property.
2012 Arkansas Fire Code 507.1

The 13,080 sq ft building will need fire sprinklers.
2012 Arkansas Fire Code 903.2.9

The 12,420 sq ft building will need fire sprinklers.
2012 Arkansas Fire Code 903.2.9

The 4,900 sq ft buildings will need to be separated by a minimum of 10'.
2012 Arkansas Building Code Chapter 6

Marc Trollinger
Fire Marshal