



BENTON COUNTY FIRE SERVICES

Marc Trollinger, Fire Marshal
215 E. Central Ave, Bentonville, AR 72712
Phone: 479-271-1004 Fax: 479-271-1084
Operations: 479-271-1005
bentoncountyar.gov

2/25/2016

Tow Mate phase 2 (2/25/2016)

Building Classification S-2 (Low Hazard Storage)
2012 Arkansas Building Code 311.3

The driving surface will need to be built to support a minimum of a 50,000lb Fire Apparatus.
2012 Arkansas Fire Code 503.2.3

Any locked gates will require an electric opening device.
2012 Arkansas Fire Code 503.6

One or more fire hydrants or other approved water supply will be required on the property.
2012 Arkansas Fire Code 507.1

The driveway must have a turnaround suitable for fire apparatus 40' long or longer.
2012 Arkansas Fire Code 503.2.5

The turning radius in parking lot must be suitable to make a turn with a 40' long apparatus.
2012 Arkansas Fire Code 503.2.4

The driveway and parking lot area must be a minimum of 20' wide. The 20' wide area can not include any parking spaces.
2012 Arkansas Fire Code 503.2.1

Marc Trollinger
Fire Marshal